


ORDINANCE 506

AN ORDINANCE OF THE CITY OF MORGANFIELD, KENTUCKY,
ESTABLISHING DOW'S RECOMMENDED DAILY MAXIMUM POLLUTANT
FOR THE CITY'S PRETREATMENT SEWER USE ORDINANCE

BE IT ORDAINED BY THE CITY OF MORGANFIELD, KENTUCKY, AS
FOLLOWS:


K- Local Limits Section 7 - Maximum Daily Limits for Pollutants:

<u>Pollutants</u>	<u>Daily Maximum</u> (milligrams per liter)
Arsenic	0.24
Cadmium	0.01
Chromium, Total	1.00
Chromium, Hexavalent	0.45
Copper	0.19
Cyanide	0.36
Lead	0.20
Mercury	0.0005
Molybdenum	0.79
Nickel	1.40
Selenium	0.12
Silver	0.1
Zinc	1.0



Bill Young
Mayor

ATTEST:



David F. Presser
City Administrator

First Reading: February 27, 2014
Second Reading: March 27, 2014
Publish: May 7, 2014